

Herz Valve type TS-90

Thermostatic valves shall be manufactured in accordance with EN215 and shall be of cast brass construction with 'O'-ring seal, rated PN10. Removal of the valve insert must be achievable while the system is live and under full working conditions using a dedicated tool, allowing subsequent replacement or servicing. The seal shall be of Torus design giving a smaller area of contact. The valve manufacturer shall provide a five year fully comprehensive warranty, covering parts, labour and consequential loss.